***DEPARTMENT OF BEHAVIORAL HEALTH AND DEVELOPMENTAL SERVICES***
***CORRECTIVE ACTION PLAN***



License #: **2240-14-009**
Organization Name: **Center for Discovery**

Date of Inspection: **01-17-2023**
Program Type/Facility Name: **14-009 Center for Discovery- Monterey**

| Standard(s) Cited | Comp | Description of Noncompliance | Actions to be Taken | Planned Comp. Date |
|---|---|---|---|---|
| 12VAC35-46-450. C. - Precautions shall be taken to prevent scalding from running water. Water temperatures shall be maintained between 100°F and 120°F. | N | Center for Discovery- Monterey<br><br>This regulation was NOT MET as evidenced by:<br><br>At the time of inspection, the water temperature could not be maintained within a range of 100-120°F as it was 127.4°F. | PR) 03/03/2023<br><br>Program Administrator adjusted water heater temperature threshold to adjust for a temperature no higher than 116 degrees Fahrenheit. Temperatures will be taken daily and adjusted should there be a temperature outside of necessary range 100-120 degrees Fahrenheit.<br><br>OLR) Accepted 03/07/2023 | 1/18/2023 |

**General Comments / Recommendations:**

I understand it is my right to request a conference with the reviewer and the reviewer's supervisor should I desire further discussion of these findings. By my signature on the Corrective Action Plan, I pledge that the actions to be taken will be completed as identified by the date indicated.

Kecia David, Licensing Specialist | (Signature of Organization Representative) | Date

C = Substantial Compliance, N = Non Compliance, NS = Non Compliance Systemic, ND = Non Determined